



STABILITETSUTREDNING, BRANDKÄRR


Sektion: 77/160V

Delområde: Brandkärr

Analysmetod: Odränerad analys

Skala: 1:800 (A3)

Slip Surface Option: Grid and Radius
Method: Morgenstern-Price
PWP Conditions from: Spatial Function
Date: 2020-02-04
Created By: Jonsson Erik
Last Edited By: Jonsson Erik



Name: Erosionsskydd
Model: Mohr-Coulomb
Unit Weight: 18 kN/m³
Cohesion: 0 kPa
Phi: 42 °

Name: Fyllning
Model: Mohr-Coulomb
Unit Weight: 18 kN/m³
Cohesion: 0 kPa
Phi: 34 °

Name: Lera 1 U
Model: S=f(datum)
Unit Weight: 15,9 kN/m³
C-Datum: 12 kPa
C-Rate of Change: 0 (kN/m²)/m
Datum (Elevation): 1 m

Name: Lera 2 U
Model: S=f(datum)
Unit Weight: 15,9 kN/m³
C-Datum: 12 kPa
C-Rate of Change: 1,3 (kN/m²)/m
Datum (Elevation): -4 m

Name: Lera AB U
Model: S=f(datum)
Unit Weight: 15,9 kN/m³
C-Datum: 3 kPa
C-Rate of Change: 3,09 (kN/m²)/m
Datum (Elevation): -7 m

Name: Lera AS U
Model: S=f(depth)
Unit Weight: 15,9 kN/m³
C-Top of Layer: 3 kPa
C-Rate of Change: 3,09 (kN/m²)/m

Name: Lot
Model: Mohr-Coulomb
Unit Weight: 15,9 kN/m³
Cohesion: 0 kPa
Phi: 30 °

Höjdsystem: RH 2000